



MINIMUM WALL THICKNESS IN ORDER TO CREATE A MINIMUM 7" GAP BETWEEN FABRIC

DSI-FW119 DEPLOYABLE FABRIC FIREWALL

5-3/4" MINIMUM

4"

4"

2"

2"



www.doorsysinc.com

DSI-FW119 DEPLOYABLE FABRIC FIREWALL
 JAMB DETAIL OPTION 3A, INSET IN WALL FLUSH

SCALE: 6"=1'-0"
 DRAWN: 09/20/23

JAMB OPTION #3A