

Guardian Fire Testing Laboratories, Inc.

114 Lincoln Avenue
Cobleskill, New York 12043
www.firetesting.com

Product Certification

Accredited to ISO 17065 through ANAB (ANSI National Accreditation Board)

Door Systems Inc.


1150 Las Brisas
Placentia, CA 92870

Products Certified:

DSI-HSM10B Manual Hose Stream Rated Smoke and Fire Shutter

(For use in gypsum or masonry wall type constructions, maximum 144in wide by 120in high. When greater than 144in wide by 120in high, the single barrel and multibarrel assemblies are eligible for an Oversized label and may be produced up to 19.7ft wide by 39.4ft high for the single barrel assemblies, and up to 984.3ft wide by 39.4ft high for the multibarrel assemblies.)

Tested to: UL 10B and ASTM E2226 (180 minutes with hose stream)
Guardian Report: GR-4-2-24-X; Report Date: August 15, 2024



Authorized Guardian Signature



Reliable, responsive,
and recognized since 1994.

Certifying Product Reliability Against Fire

Issue Date: January 9, 2025
Expiration Date: January 31, 2026