



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE  
PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	4076-2312:0500
<b>PARENT LISTING No.:</b>	4076-2311:0500
<b>CATEGORY:</b>	4076 - SMOKE & DRAFT CONTROL FOR FIRE DOOR
<b>LISTEE:</b>	Door Systems, Inc. 1150 Las Brisas Place, Placentia, CA, 92870 Contact: Bonnema, Jeff (714) 222-3769 (714) 258-7171 Email: jeff@doorsysinc.com
<b>DESIGN:</b>	<p>Models DSI-D1HRS, DSI-D1HRM, DSI-D3HRS, DSI-D3HRM, DSI-600 ELEV1S, DSI-600 ELEV1M, DSI-600 ELEV3S, and DSI-600 ELEV3M fire-protective smoke curtains consist of a woven glass fiber, silver polyurethane coated fabric attached to rollers contained within a surface or between-jamb mounted steel curtain box. The curtain shall overlap a minimum 19.7 in. for multiple barrel assemblies. The maximum opening size is 236.2 in. wide by 472.4 in. high for single barrel assemblies and 1417.3 in. wide by 472.4 in. high for multiple barrel assemblies.</p> <p>Refer to listee's data sheet for additional product description and operational considerations.</p>
<b>RATING:</b>	<p>UL10D:</p> <p>Models DSI-D1HRS, DSI-D1HRM - 1 hr classification</p> <p>Models DSI-D3HRS, DSI-D3HRM - 3 hr classification</p> <p>UL 1784:</p> <p>Models DSI-600 ELEV1S, DSI-600 ELEV1M, DSI-600 ELEV3S, DSI-600 ELEV3M:</p> <p>1.57 CFM/FT<sup>2</sup> ambient; 0.47 CFM/FT<sup>2</sup> 400°F; 0.05" water column</p> <p>2.31 CFM/FT<sup>2</sup> ambient; 0.79 CFM/FT<sup>2</sup> 400°F; 0.10" water column</p> <p>5.28 CFM/FT<sup>2</sup> ambient; 2.91 CFM/FT<sup>2</sup> 400°F; 0.20" water column</p> <p>14.00 CFM/FT<sup>2</sup> ambient; 0.30" water column</p>
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, and UL label.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE  
PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>APPROVAL:</b>	Listed as fire-protective smoke curtains for use in gypsum or masonry wall type constructions. For use where allowed by the California Building Code and the authority having jurisdiction. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	This item is for nonstructural applications and NO hose stream tests were conducted.

03-02-20 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 06/28/2023**

**Listing Expires: 06/30/2024**

Authorized By: **Victor Wong** , Program Coordinator  
Fire Engineering & Investigations Division