

# Guardian Fire Testing Laboratories, Inc.

114 Lincoln Avenue  
Cobleskill, New York 12043  
www.firetesting.com

## Product Certification

Accredited to ISO 17065 through ANAB (ANSI National Accreditation Board)

### Door Systems Inc.

1150 Las Brisas  
Placentia, CA 92870


### Products Certified:

#### DSI-HHS10B Hose Stream Rated Horizontal Fire Curtain

(For use in gypsum or masonry wall type constructions, maximum 10'-9" wide by 11'-5" travel. When greater than 10'-9" wide by 11'-5" travel, an Oversized Label may be produced up to 32'-10" wide by 32'-10" travel for single parting curtains and up to 65'-8" travel for bi-parting curtains.)

Tested to: UL 10B and ASTM E2226 (120 minutes with hose stream)

Guardian Report: EER-8-31-23-Z; Report Date: 9/25/2023



Authorized Guardian Signature



Reliable, responsive,  
and recognized since 1994.

***Certifying Product Reliability Against Fire***