

ICC-ES Evaluation Report

ESR-4761 CBC and CFC Supplement

Reissued January 2024

This report is subject to renewal January 2026.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION Section: 07 87 00—Smoke Containment Barriers

DIVISION: 08 00 00—OPENINGS Section: 08 30 00—Specialty Doors and Frames

REPORT HOLDER:

DOOR SYSTEMS

EVALUATION SUBJECT:

MODEL DSI-600 ELEVATOR SMOKE CONTAINMENT SYSTEM

1.0 REPORT PURPOSE AND SCOPE

Purpose:

The purpose of this evaluation report supplement is to indicate that Model DSI-600 Elevator Smoke Containment System, described in ICC-ES evaluation report ESR-4761, has also been evaluated for compliance with CBC Chapters 7 and 30 and CFC Chapters 1, 7 and 9 of the code editions noted below.

Applicable code editions:

■ 2019 California Building Code (CBC)

For evaluation of applicable chapters adopted by the California Office of Statewide Health Planning and Development (OSHPD) AKA: California Department of Health Care Access and Information (HCAI) and the Division of State Architect (DSA), see Sections 2.1.1 and 2.1.2 below.

■ 2019 California Fire Code (CFC)

2.0 CONCLUSIONS

2.1 CBC:

The Model DSI-600 Elevator Smoke Containment System, described in Sections 2.0 through 7.0 of the evaluation report ESR-4761, complies with CBC Section 3006.3 (Items 2, 3 and 5) and CBC Section 710.5.2.2, provided the design, installation, inspection and maintenance are in accordance with the 2018 *International Building Code*[®] (IBC) provisions noted in the evaluation report and the additional requirements of the CBC, as applicable.

2.1.1 OSHPD: The applicable OSHPD Sections of the CBC are beyond the scope of this supplement.

2.1.2 DSA: The applicable DSA Sections of the CBC are beyond the scope of this supplement.

2.2 CFC:

The Model DSI-600 Elevator Smoke Containment System, described in Sections 2.0 through 7.0 of the evaluation report ESR-4761, complies with CFC Sections 108, 705.2 and 909.12, provided the design, installation, inspection and maintenance are in accordance with the 2018 *International Fire Code*[®] (IFC) provisions noted in the evaluation report and the additional requirements of the CFC, as applicable.

This supplement expires concurrently with the evaluation report, reissued January 2024.

