

CERTIFICATE OF COMPLIANCE

Certificate Number R39636
Report Reference R39636-2018-09-19
Issue Date 2023-09-27

Issued to: Door Systems Inc
1150 Las Brisas Pl
Placentia, CA 92870 United States

This certificate confirms that representative samples of Leakage-rated Door Assemblies
See addendum for model information

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1784, Air Leakage Tests of Door Assemblies and Other Opening Protectives, Edition 4

Additional Information: See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number R39636
Report Reference R39636-2018-09-19
Issue Date 2023-09-27

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Door Model(s): DSI-HS10B S90 Hose Stream Rated Smoke and Fire Shutter, DSI-HS10B M90 Hose Stream Rated Smoke and Fire Shutter, DSI-HS10B S180 Hose Stream Rated Smoke and Fire Shutter, DSI-HS10B M180 Hose Stream Rated Smoke and Fire Shutter.

Frame Model: Head Box and Bottom Bar

Perimeter Seals: N/A

Bottom Seals: Bottom Bar / Artificial Bottom Seal

Hardware: N/A Accessories:

N/A Ratings:

Pressure (in. of WC)	Air Temp. °F	Leakage (cfm/sq ft)	Closing Force, lb	Artificial Bottom Seal
0.050	Ambient	2.23	N/A	No
0.100	Ambient	2.86	N/A	No
0.200	Ambient	6.97	N/A	No
0.280	Ambient	13.50	N/A	No
0.050	400	1.24	N/A	No
0.100	400	1.45	N/A	No
0.200	400	3.17	N/A	No
0.300	400	7.41	N/A	No
0.050	Ambient	2.11	N/A	Yes
0.100	Ambient	2.50	N/A	Yes
0.200	Ambient	3.60	N/A	Yes
0.300	Ambient	4.77	N/A	Yes
0.050	400	1.10	N/A	Yes
0.100	400	1.43	N/A	Yes
0.200	400	1.77	N/A	Yes
0.300	400	2.28	N/A	Yes

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>

